



Certificate of Compliance

Certificate Number: LR 55274-24

Revision:

Date Issued: January 16, 1997

Issued to: **OGDEN MANUFACTURING COMPANY**
64 W. Seegers Rd.
Arlington Heights, IL 60005 USA
Attention: Mr. Joe Trass

The products listed below are eligible to bear the CSA Mark

NOTE: *The "NRTL/C" indicator also appears adjacent to the CSA Mark.*

Issued by: D. Somma, C.E.T.
Toronto, ON Canada

Signature:

PRODUCTS

CLASS 2878 02 - HEATERS - Miscellaneous - For Hazardous Locations

CLASS 2878 82 - HEATERS - Miscellaneous - For Hazardous Locations - CERTIFIED TO U.S. STANDARDS

Class I, Div. 1, Groups B, C and D; Class II, Groups E, F and G; Class III

- Immersion heaters, screw plug type, Series KF-1, KI-1, KI-2, KI-3, KIX-1, KV-1, KV-2, KV-3, KR-3, KG-1, KJ-1, KJ-2, KJ-3, KJX-1, KW-1, KW-2, KW-3, KS-3, KE-1, KH-2, KH-3, KB-2, KB-3, KQ-3, KG-1, suffix -M7, with or without thermostat, rated 600V ac max, 25 KW max, 200 w/sq in max, single or three phase.

- Immersion heaters, flange type, Series K3C, K4C, K5C, K6C, K8C, K10C, K12C, K14C, K3A, K4A, K5A, K6A, K8A, K10A, K12A, K14A, K3S, K4S, K5S, K6S, K8S, K10S, K12S, K14S, suffix -M6 or -M7, with or without thermostat, rated 600V ac max, 225 KW max, 200 w/sq in max, single or three phase.

- Circulation heaters, Series C, suffix -M6 or -M7, with or without thermostat, rated 600V ac max, 70 KW max, 200 w/sq in max, single or three phase.

The "NRTL/C" indicator adjacent to the CSA Mark signifies that the product has been evaluated to the applicable ANSI/UL and CSA Standards, for use in the U.S. and Canada. NRTL, i.e. Nationally Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards.